

FINAL REPORT

CERTIFICATE No.: 26971



Boral Cement Limited

ABN 62 008 528 523

Taylor Avenue New Berrima NSW 2577

Locked Bag 4 New Berrima NSW 2577

T +61 2 4860 2222

TEST CERTIFICATE OF: Tarong Daily Despatch Grade 1 Fly Ash
PRODUCED AT: Boral Cement Limited Tarong
TESTED AT: Berrima Works Laboratory
SAMPLE IDENTIFICATION: TDDFA2500888
DATE DESPATCHED: 13/03/2025

| PROPERTY | REQUIREMENTS OF AS 3582.1 - Grade 1 | RESULT |
|--|-------------------------------------|---------|
| Fineness (AS 3583.1) | ≥ 75 % | 87 % |
| LOI (AS 3583.3) | ≤ 4.0 % | 2.9 % |
| Moisture (AS 3583.2) | ≤ 0.5 % | < 0.1 % |
| SiO ₂ (AS 2350.2) | | 69.3 % |
| Al ₂ O ₃ (AS 2350.2) | | 23.8 % |
| Fe ₂ O ₃ (AS 2350.2) | | 1.2 % |
| Chemical Composition (AS 2350.2) | ≥ 70 % | 94 % |
| Total Alkali (AS 2350.2) | | 0.4 % |
| Cl (AS 2350.2) | ≤ 0.1 % | 0.00 % |

REMARKS

Sampling not carried out by laboratory. Samples tested as received and results only relate to the item tested.



Accredited for compliance with ISO/IEC 17025 - Testing

A handwritten signature in blue ink, appearing to read "SNAPPA".

Jason Nairn
National Technical Manager



Building something great

Unit 4, 3-5 Gibbon Road,
Baulkham Hills NSW 2153 Australia
PO Box 400,
Winston Hills NSW 2153

T +61 (02) 9624 9900
boral.com.au

TEST REPORT – FLYASH

CLIENT: BORAL CEMENT – (TECHNICAL)

FILE NO: 50/25

ADDRESS: 39 Delhi Road, North Ryde, NSW 2113

REQUEST NO: 117691

SAMPLE IDENTIFICATION: TDDFA2500888

LAB SAMPLE NO: 318755

SOURCE OF SAMPLE: Queensland

DATE SAMPLED: 13/03/2025

DATE RECEIVED: 17/03/2025

IDENTIFICATION OF CEMENT USED: Boral Cement SL Berrima Ref. 2022

TEST METHOD: AS 3583: Methods of test for supplementary cementitious materials for use with Portland cement

| PROPERTY | DATE TESTED | RESULT | TEST METHOD |
|--|-------------|--------|-------------|
| Relative density | 25/03/2025 | 2.11 | AS 3583.5 |
| Relative water requirement | 27/03/2025 | 102% | AS 3583.6 |
| Relative strength 7 days (accelerated) | 03/04/2025 | 95% | AS 3583.6 |
| Relative strength 28 days (standard) | 24/04/2025 | 94% | AS 3583.6 |

Note:

- Sample supplied by the client and tested as received.

Melody Mancenido, Rebecca Jordan, Mat. File, File

Approved signatory _____

Sam El-Hamawi
CEM117691.SE.1

Date 24/04/2025 Serial no. _____

